



VRBR.E35388
Switches, Pressure for Use in Hazardous Locations

[Page Bottom](#)

Switches, Pressure for Use in Hazardous Locations

[See General Information for Switches, Pressure for Use in Hazardous Locations](#)

POTTER ELECTRIC SIGNAL CO L L C
1609 PARK 370 PL
HAZELWOOD, MO 63042-4417 USA

E35388

Class I, Groups B, C and D; Class II, Groups E, F and G.

Models PS10-EX, PS40-EX.

[Last Updated](#) on 1996-01-10

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2014 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2014 UL LLC".

Electrical Signaling

Electrical protective signaling systems are configurations of components used to produce alarm signals indicative of fire, smoke, sprinkler waterflow or other emergency and to produce supervisory signals indicative of conditions needing attention with respect to protection equipment or watch service. System configurations are classified according to where and how the signals are received. The categories are commonly designated as local, municipal, remote station, proprietary, emergency voice/alarm communication, emergency communication, and central station. Auxiliary systems are either local or proprietary systems interconnected with a municipal system.

This category presents the major system component categories and the integrated system configurations. The selection of components to form a hybrid system should be made only by those skilled in system design. Also, the suitability of any system application should be judged on the basis of the hazard(s) being protected.

Alarm Signal Initiating Devices

Alarm signals are initiated either automatically or manually. Automatic detectors respond to changes in characteristic phenomena associated with fire or other emergency conditions.

Sprinkler Waterflow, Pressure-Actuated

These waterflow alarm switches and switch-actuated transmitters are pressure activated and are used with waterflow alarm check valves, dry pipe valves or automatic water control valves. See also WATERFLOW ALARM VALVES and WATERFLOW DETECTORS, VANE TYPE. Unless otherwise noted in the listing, these devices have 175 psi (1205 kPa) rated working pressure.

Model PS10-EX

Pressure Switch. Model PS10-EX. For wet and dry pipe sprinkler systems. This adjustable switch has an operating pressure range of 4 to 20 psi (28 to 138 kPa). Switch contacts are rated for 10 A at 125/250 V ac, 2.5 A at 30 V dc. Pressure switch is rated NEMA Type 4, suitable for indoor/outdoor use with an operating temperature range of -40° to 140°F (-40° to 60°C). Pressure switch is explosionproof for Class I, Division 1, Groups B, C and D; Class II/III, Division 1, Groups E, F, and G hazardous (classified) locations.

Company Name:	Potter Electric Signal Company
Company Address:	1609 Park 370 Place, Saint Louis, Missouri 63042, USA
Company Website:	http://www.pottersignal.com
New/Updated Product Listing:	No
Listing Country:	United States of America
Certification Type:	FM Approved